

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0476:114 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Harrington Signal Inc., 2519 4th Ave, Moline, IL 61265
Contact: Andrew Keller (309) 762-0731

DESIGN: Model HS-3400 fire alarm control unit. Power-limited; non-coded, local, manual, automatic, central station (protected premises), waterflow and sprinkler supervisory service. Also suitable for releasing service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

HS-3400	Control Unit
MR-2905	Power Supply

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and indicating devices.

*This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition. Refer to manufacturer's Installation Manual for details.

XLF: 7165-1429:102

*Corrected 01-19-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager